
Walla Walla Public Schools

Summary Sheet

Asbestos Containing Materials (Listed by School)

- **Berney Elementary School**
1718 Pleasant Street
 - Cement asbestos board (CAB) on soffits and eaves
 - Floor tile adhesives only (12' x 12' are non ACM)
 - Boiler gaskets

- **Blue Ridge Elementary School**
1150 West Chestnut Street
 - Adhesive associated with vinyl floor tile

- **Edison Elementary School**
1315 East Alder
Built in 2009
 - No asbestos

- **Green Park Elementary School**
1105 Isaacs
 - Asbestos containing building material (ACBM) under roof soffits in 1905 building
 - No asbestos in 1995 building

- **Lincoln Alternative**
421 South 4th Street
 - Boiler insulation and TSI piping the boiler room
 - 9" x 9" floor tiles and mastic
 - 12" x 12" floor tiles and mastic
 - TSI piping insulation and fittings throughout basement area, gymnasium
 - Cement asbestos board (CAB) on exterior of windows – limited areas

- **Prospect Point Elementary School**
55 Reser Road
 - TSI fittings on plumbing located by under counter HW heaters
 - Thermal system insulation on joints, elbows, and tees

- **Sharpstein Elementary School**
410 Howard
 - Felt paper between wooden floors, 2nd and 3rd floors, in the west section (1904 building)
 - Vermiculite insulation in ceiling and between floors
 - Built-up roofing in attic spaces

● **Garrison Middle School**

906 Chase

- TSI piping insulation not accessible inside wall cavities
- Fire door in boiler room

● **Pioneer Middle School**

450 Bridge

- Possible abandoned TSI in tunnel systems
- Cement asbestos board on exterior door panel

● **Walla Walla High School**

800 Abbott

- 9" x 9" VAT floor tiles and mastic throughout 1964 buildings
- Hot water tank wrap in Commons Building
- Mudded fittings on piping from HW tank
- 2' x 4' suspended ceiling tile panels in Commons Building.
- Hot water tank wrap in small gym
- 12 x 12 Vinyl floor tile and adhesive
- Cement asbestos board
- Thermal system insulation on blast furnaces

● **Opportunity Program**

1917 E Isaacs

- Cement asbestos board on ceiling throughout

● **District Administrative Building**

364 South Park

Built in 1985

- No asbestos

● **Support Services Building**

1174 Entley Street

Built in 2011

- No asbestos

● **Transportation Co-Op Building**

1162 Entley Street

Built in 2010

- No asbestos